



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00582

OWNER'S NAME: ODELL

DATE: 3/14/2017

TYPE: Framing

TIME STARTED: 3:06 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-19-33020-0028

1. Trusses ok
2. Framing ok
3. Install draftstop at sttic duct penetration upstairs
4. Fireplace not installed yet

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506