



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00597

OWNER'S NAME: LEENSVART

DATE: 10/19/2016

TYPE: Slab plumbing

TIME STARTED: 12:52 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-28000-0046

1. Slab Plumbing OK. DXV at 5#/15min. OK.
2. Slab Insulation OK. Thermal Break OK.

INSTRUCTIONS: OK to Pour Floor

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506