



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00598

OWNER'S NAME: WALTERS

DATE: 10/12/2016

TYPE: Gas piping

TIME STARTED: 3:15 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-22050-0125

1. Gas Line at 15#/15min. OK.
2. Fireplace Rough In OK.

INSTRUCTIONS: Ok to Connect Gas

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506