



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00612

OWNER'S NAME: SELBY

DATE: 2/1/2017

TYPE: Multiple (see notes)

TIME STARTED: 10:54 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-19-17000-0003

1. DWV not on test
2. Supply Live - Ok
3. Plumbing RI Ok
4. Mechanical not complete
5. Gas @ 18#/15 mins - Ok
6. Framing Ok
7. Porch Framing not complete - Verify next inspection
8. NOTE: Exterior walls spray foamed @ time of inspection

INSTRUCTIONS: DO NOT INSULATE/Complete above/Complete L&I

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506