



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00612

OWNER'S NAME: SELBY

DATE: 2/10/2017

TYPE: Re-inspection

TIME STARTED: 12:39 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-17000-0003

1. Plumbing Rough In Corrections OK. DWV on Stack Test OK.
2. Mechanical Exhaust OK.
3. NOTE: Porch Footings and Posting To BE Done Once Ground Thaws.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506