## **INSPECTION REPORT**

PERMIT NUMBER:	BP-16-00618	OWNER'S NAME:	FORTUNE CREEK LLC
DATE:	3/1/2017	TYPE:	Rough-in plumbing
TIME STARTED:	10:47 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-15-07061-0044		
1. Corrections O 2. DWV @ 5#/15 3. Supply @ 70# 4. Plumbing RI O 5. Mechanical in 6. Range hood in	5 mins - Ok #/15 mins - Ok Ok progress		
INSTRUCTIONS: Complete mechanical and electrical			
NEXT INSPECTION:	Mechanical		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDRESS: <u>justin.bennett</u> @co.kittitas.wa.us		

**INSPECTION REQUEST LINE: 509-962-7694** 

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506