INSPECTION REPORT

PERMIT NUMBER:	BP-16-00618	OWNER'S NAME:	FORTUNE CREEK LLC
DATE:	3/28/2017	TYPE:	Re-inspection
TIME STARTED:	12:59 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	19-15-07061-0044		
 Framing corections ok Wall insulation ok. R-21 batt with poly vapor barrier Vault insulation ok. R-38 batt Address insulation covering chimney pipe. 			
INSTRUCTIONS:			
NEXT INSPECTION: Re-inspect chimney			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: iessica.contratto @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506