## **INSPECTION REPORT**

PERMIT NUMBER:	BP-16-00618	OWNER'S NAME:	FORTUNE CREEK LLC
DATE:	5/26/2017	TYPE:	Final
TIME STARTED:	10:21 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-15-07061-0044		
<ol> <li>Access expired</li> <li>Fireplace not functional</li> <li>Range not functional</li> <li>(9) Foundation vents required - (6) foundation vents installed</li> <li>Blower door not on site</li> </ol>			
INSTRUCTIONS: C	omplete above		
NEXT INSPECTION:	Re-Inspection		
RE-INSPECTION FEE DUE? VES \$  IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDRESS: <u>justin.bennett</u> @co.kittitas.wa.us		

**INSPECTION REQUEST LINE: 509-962-7694** 

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506