



KITTTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00621

OWNER'S NAME: TROUT

DATE: 6/2/2017

TYPE: Mechanical

TIME STARTED: 3:22 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0084

1. Mechanical OK.
2. Supply Return OK.
3. Mechanical Exhaust OK.
4. Gas Line OK. 20#/15min. OK.
5. FIREPLACE ROUGH IN NOT COMPLETE.
6. NOTE: Kitchen Sink DWV Not Vented.

INSTRUCTIONS: Complete Fireplace Chase Dractstop

NEXT INSPECTION: Plumbing.

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506