



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00623

OWNER'S NAME: LAUB

DATE: 2/23/2017

TYPE: Exterior shear

TIME STARTED: 11:14 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29050-0021

1. Exterior nailing and straps ok
2. Straps horizontal at cantilevered beams ok. On exterior

INSTRUCTIONS: Ok to cover exterior

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506