



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00637

OWNER'S NAME: LIPES

DATE: 6/21/2017

TYPE: Mechanical and plumbir

TIME STARTED: 12:54 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-17-33000-0013

1. DWV @ 7#/15 mins - Ok
2. Supply @ 70#/15 mins - Ok
3. Plumbing RI Ok
4. Mechanical Ok
5. OA to Return installed - Ok
6. Gas @ 20#/15 mins - Ok

INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ justin.bennett@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506