INSPECTION REPORT

INST ECTION KET OKT			
PERMIT NUMBER:	BP-16-00637	OWNER'S NAME:	LIPES
DATE:	6/23/2017	TYPE:	Framing
TIME STARTED:	11:40 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-17-33000-0013		
1. Provide Truss Manufacturer fix/approval for Garage trusses @ 77# snow load - truss sheets indicate 70# snow load 2. Garage Header 6x10 - Sheet 9 calls for 6x12 3. Fireplace RI Ok			
INSTRUCTIONS: Complete above/Verify @ Insulation			
NEXT INSPECTION: Insulation			
RE-INSPECTION FEE	DUE? V NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: justin.bennett @co.kittitas.wa.us			
INCRECTION REQUEST LINE, 500 063 7604			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506