



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00641

OWNER'S NAME: KITTITAS CO

DATE: 3/9/2017

TYPE: Gas piping

TIME STARTED: 1:43 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-24050-0002

1. Gas Piping To (2) Mechanical Mezzanines OK. 20#/15min. OK.

INSTRUCTIONS: OK to Set Meter When Ready.

NEXT INSPECTION: Duct Insulation/Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506