



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00641

OWNER'S NAME: KITTITAS CO

DATE: 3/22/2017

TYPE: Insulation and mechanic

TIME STARTED: 9:47 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-18-24050-0002

1. Volume damper installation Ok
2. Tighten up insulation @ duct heater in W corridor
3. Patch insulation @ duct in S corridor W of reception at conduit
4. NOTE: Cx Agent required per contract

INSTRUCTIONS: Complete Furnace, refrigerant line and condensate installation

NEXT INSPECTION: Furnace RI

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506