INSPECTION REPORT

PERMIT NUMBER:	BP-16-00676	OWNER'S NAME:	TRAILSIDE HOMES
DATE:	3/29/2017	TYPE:	Rough-in plumbing
TIME STARTED:	11:18 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-14-13050-0004		
 Garage Supply @ 65#/15 mins - Ok Garage DWV @ 0# - Needs to be 5# Garage strip footing missing @ stairs House Supply @ 75#/15 mins - Ok House DWV @ 2# - Needs to 5# Corrections Ok NOTE: Permit card not on site NOTE: Foundation dwg missing to confirm footing @ stair 			
INSTRUCTIONS: Pressurize DWV @ house and garage/Install footing/confirm on dwg			
NEXT INSPECTION:	Re-Inspection		
RE-INSPECTION FEE DUE? VES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>justin.bennett</u> @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506