



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00676

OWNER'S NAME: TRAILSIDE HOMES LLC

DATE: 5/2/2017

TYPE: Insulation

TIME STARTED: 10:19 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-13050-0004

1. Corrections not complete from previous report
2. DO NOT COVER
3. Wall insulation R-21 batt with vapor barrier
4. Vault insulation R-38 batt. Vapor barrier installed in vaulted areas

INSTRUCTIONS: Complete above, re-inspect fee due. DO NOT COVER

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jessica.contratto @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506