



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00695

OWNER'S NAME: RICHTER

DATE: 11/21/2016

TYPE: Rough-in plumbing

TIME STARTED: 10:38 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-16-31020-0007

1. Slab Insulation Ok
2. Slab Plumbing not on Test

INSTRUCTIONS: Slab plumbing must be on test/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506