



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00695

OWNER'S NAME: RICHTER

DATE: 11/22/2016

TYPE: Re-inspection

TIME STARTED: 2:18 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-16-31020-0007

1. Slab Plumbing OK. Stack Test.

INSTRUCTIONS: OK to Backfill and Pour

NEXT INSPECTION: Shearwalls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506