



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00695

OWNER'S NAME: RICHTER

DATE: 12/7/2016

TYPE: Shearwalls

TIME STARTED: 2:52 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 21-16-31020-0007

1. Not ready
2. Not all shearwalls installed - nailing cannot be performed

INSTRUCTIONS: Complete shearwall construction

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506