



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00697

OWNER'S NAME: HOLLEY

DATE: 3/30/2017

TYPE: Rough-in mechanical

TIME STARTED: 11:28 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-20058-0082

1. Gas @ 21#/15 mins - Ok
2. Exhaust Ok
3. OA confirmed - Ok
4. Upstairs SA Ok
5. Underfloor SA in progress

INSTRUCTIONS: Complete Underfloor Ducting/Verify @ plumbing

NEXT INSPECTION: Plumb

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506