



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00700

OWNER'S NAME: STYSKEL

DATE: 5/25/2017

TYPE: Rough-in plumbing

TIME STARTED: 1:04 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29051-0032

1. Straps missing at trash room man door
2. DWV on stack-ok
3. H2O is live
4. LVL rafter cut out for fireplace chimney will need addressed

### INSTRUCTIONS:

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506