INSPECTION REPORT

| PERMIT NUMBER: | BP-16-00716 | OWNER'S NAME: | GIRARD |
|--|------------------|--------------------|-------------------|
| DATE: | 4/18/2017 | TYPE: | Footings |
| TIME STARTED: | 2:08 PM | INSPECTOR: | Jessica Contratto |
| MAP NUMBER: | 20-16-26000-0066 | | |
| Remaining 2 interior pads ok HDU4's and framing in front garage return walls ok. Contractor wishes to sheath interior for added structure stability | | | |
| INSTRUCTIONS: O | k to pour | | |
| | | | <u> </u> |
| RE-INSPECTION FEE | | DAID DRIOD TO SCUE | \$ |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL | | | |
| ADDRESS: <u>iessica.contratto</u> @co.kittitas.wa.us | | | |
| INSDECTION PEOLIEST LINE: E00 062 7604 | | | |

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506