



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-16-00729

OWNER'S NAME: TALISMAN

DATE: 4/19/2017

TYPE: Plumbing

TIME STARTED: 1:28 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19056-0013

1. DWV has a leak @ the Y from the upstairs tub (3")
2. Supply @ 70#/15 mins - Ok
3. Gas @ 17#/15 mins - Ok

INSTRUCTIONS: Repair DWV/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506