INSPECTION REPORT

IIIOI ECITOR NEI ORI			
PERMIT NUMBER:	BP-16-00735	OWNER'S NAME:	TALISMAN
DATE:	5/9/2017	TYPE:	Insulation
TIME STARTED:	12:41 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-19056-0014		
 Corrections ok Wall insulation R-21 batt with vapor barrier Vault insulation R-38 batt with vapor barrier Floor insulation not installed at this time 			
instructions: O	k to cover		
NEXT INSPECTION:	Final		
RE-INSPECTION FEE	DUE? VES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
ADDRESS: iessica.contratto @co.kittitas.wa.us			

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506