



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00754

OWNER'S NAME: FITZGERALD

DATE: 1/27/2017

TYPE: Post holes

TIME STARTED: 10:27 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-19-20010-0004

1. Setbacks Ok
2. Post holes Ok
3. NOTE: Ensure placed concrete is protected from freezing while curing

INSTRUCTIONS: Ok to pour (Concrete scheduled for the afternoon today, 1/27/17)

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506