



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00776

OWNER'S NAME: TALISMAN VILLAGE

DATE: 6/23/2017

TYPE: Mechanical and plumbir

TIME STARTED: 2:00 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-19056-0074

1. NOTE: Interior Shear Corrections Not Complete - Verify HD's and Straps @ Framing
2. Plumbing Rough In OK. DWV on Stack Test. OK.
3. NOTE: Plumbing Supply Not On Test. Must Be Verified at Next Inspection.
4. Fireplace Rough In Not Complete.
5. Mechanical Rough In of Mini Splits OK.
6. Mechanical Exhaust Not Complete Throughout..

INSTRUCTIONS: Complete Above

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506