



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-16-00788

OWNER'S NAME: HART

DATE: 5/18/2017

TYPE: Framing

TIME STARTED: 3:50 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-20-29000-0001

1. Corrections Ok
2. Gas @ 15#/15 mins - Ok
3. DWV rerouted - Ok
4. Range vent will need to be insulated
5. Rafters Ok
6. Framing Ok
7. Fireplace RI Ok

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506