



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00042

OWNER'S NAME: ZAYIC

DATE: 4/11/2017

TYPE: Mono pour

TIME STARTED: 11:02 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-16-34050-0005

1. Setbacks OK. Owners Agent Provided String Line For Setback Verification.
2. Footings and Walls OK. Mono Pour.
3. NOTE: 1st Elevation Certificate On File. 2nd Required Prior to Framing.
4. NOTE: Tree Located Directly Behind Garage Will Not Meet Defensible Space Requirements Fire Marshal's WUIC Review.

INSTRUCTIONS: OK to Pour.

NEXT INSPECTION: Shearwalls.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506