



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00114

OWNER'S NAME: STROM

DATE: 7/11/2017

TYPE: Shearwalls

TIME STARTED: 8:35 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-16-26052-0003

1. SW4 wall between bath and living room windows to have 4" edge nailing. Tighten up nailing
2. All installed hold downs have incorrectly installed saddle washer. Upside down. See diagram on hold down packaging for correct installation. Lengthen bolt and raise hold down to accommodate if needed

INSTRUCTIONS: Tighten up nailing, ok to cover exterior. Interior clips to blocking to be seen later.
Correct hold downs to be seen later

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506