



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-17-00181

OWNER'S NAME: EASTMAN

DATE: 6/20/2017

TYPE: Shearwalls

TIME STARTED: 10:22 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-35058-0002

1. NOTE: Contractor intended strapping inspection
2. NOTE: Strapping installed on studs - sheathing not installed
3. Portal Framing straps Ok - (3) locations
4. STHD locations per dwg

INSTRUCTIONS: Install sheathing/Verify Exterior Nailing

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506