



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-17-00323

OWNER'S NAME: AHLERS

DATE: 7/17/2017

TYPE: Mono pour

TIME STARTED: 1:32 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-17-32056-0002

1. Setbacks Ok
2. Install traverse bar @ 48" OC per 1/S3.1

INSTRUCTIONS: Complete above/Once complete Ok to pour

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506