



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-17-00353

OWNER'S NAME: SIERRA

DATE: 7/11/2017

TYPE: Rough-in plumbing

TIME STARTED: 12:49 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24051-0715

1. Plumbing supply Live - Ok
2. DWV @ 5#/15 mins - Ok
3. Provide engineer letter verifying structural integrity for water damaged structural members
4. New water heater being installed - verify @ Final
5. New water storage tank being installed - verify @ Final
6. New ductwork in crawl being installed - verify @ Final
7. Electrical replaced due to water damage - verify L&I inspection
8. New exhaust duct being installed - verify @ insulation
9. Existing insulation was spray foam and batt - foam remains

INSTRUCTIONS: Provide engineer letter prior to insulating

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506