



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FM-17-00014

OWNER'S NAME: TALISMAN

DATE: 4/4/2017

TYPE: Fire sprinkler

TIME STARTED: 3:45 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-19056-0007

1. Bucket Test OK. 26GPM Required. 26 Gallon Per Minute Observed.
2. Piping OK.

INSTRUCTIONS:

NEXT INSPECTION: Tenting Inspection Required Prior to Cover.

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506