



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-14-00050

OWNER'S NAME: SOLE

DATE: 7/30/2014

TYPE: Footings

TIME STARTED:

INSPECTOR: Amber Green

MAP NUMBER: 19-15-04054-0005

	1. 42" x 42" x 12" spread footing missing at crawlspace/mudroom wall.
	Perimeter footings only at this time.
	Will see interior strip & pad footings at later inspection.
	Will see exterior pads at later inspection.

INSTRUCTIONS: Complete #1, then OK TO POUR.

NEXT INSPECTION: F. WALLS

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506