



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: FO-14-00101
DATE: 10/22/2014
TIME STARTED: 10:15
MAP NUMBER: 16-20-22000-0013

OWNER'S NAME: TERRELL
TYPE: Slab plumbing
INSPECTOR: Lou Whitford

1. OK SLAB INSULATION
2. OK DWV UNDERSLAB 8#S/20 MINUTES
3. OK SPREAD FOOTINGS
4. OK TO POUR

INSTRUCTIONS:

NEXT INSPECTION: SECURE BP-14 XXXXXX PERMIT PRIOR TO SHEARWALL INSP

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506