INSPECTION REPORT

PERMIT NUMBER: FO-15-00036 OWNER'S NAME: SCARSELLA

DATE:	10/20/2015	TYPE:	Slab plumbing
TIME STARTED:	2:51 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-14-24050-0214		
1. DWV II	n-Slab Plumbing on West E	End of Basement Not on	Test.
2. DWV I	n-Slab Plumbing on East E	nd of Basement OK. Sta	ack Test OK.
INSTRUCTIONS:	DO NOT COVER PLUMBI	NG ON West End of Ba	sement. All Other OK to Pour.
NEXT INSPECTION	l: Slab Plumbing.		
RE-INSPECTION F	EE DUE? V NO	YES	\$
IF R	EQUIRED, RE-INSPECTION FEES	— MUST BE PAID PRIOR TO SCI	HEDULING A RE-INSPECTION
(QUESTIONS? PLEASE CONTACT T	HE INSPECTOR AT THE FOLLO	OWING E-MAIL ADDRESS:
		ieremv.haberman @co	o.kittitas.wa.us
	ECTION REQUEST LINE: www.411 N. Ruby Street, Suite 2, Elle		quest.asp or 509-962-7694 ● Office Line: 509-962-7506