

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

PERMIT NUMBER:	FO-15-00036	OWNER'S NAME:	SCARSELLA
DATE:	11/9/2015	TYPE:	Radiant heat
TIME STARTED:	12:33 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-14-24050-0214		

1. NOTE:			
2. Radiant Tubing OK. 100#/15min.			
3. R-10 Slab Insultion OK.			
INSTRUCTIONS: OK to Pour			
NEXT INSPECTION:			
RE-INSPECTION FEE DUE? V YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			

ieremv.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506