



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: FO-16-00030

OWNER'S NAME: BUILDWORX

DATE: 10/24/2016

TYPE: Slab plumbing

TIME STARTED: 2:30 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 22-11-04053-0904

1. Slab Plumbing OK. Stack Test OK.

INSTRUCTIONS: OK to Backfill and Install Slab Insulation

NEXT INSPECTION: Slab Insulation/Radiant Tubing

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506