



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: FO-16-00057

OWNER'S NAME: STYSKEL

DATE: 11/7/2016

TYPE: Footings

TIME STARTED: 3:55 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29051-0120

1. 36x36 point load @ garage not 12" per dwgs (clouded)
2. 60x60 point load @ strip footings not 12" per dwgs (clouded)

INSTRUCTIONS: Complete above/Once complete Ok to pour

NEXT INSPECTION: Foundation Walls

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506