



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: K-94-03004

OWNER'S NAME: BROWN

DATE: 5/9/2016

TYPE: Final

TIME STARTED: 1:49 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-06020-0018

1. Provide manual for propane fireplace
2. Install exhaust venting for fireplace per installation manual
3. Provide returns @ railing
4. Install range hood or carbon recirculating hood

INSTRUCTIONS: Complete above/Re-Final

NEXT INSPECTION: Re-Inspection/Final

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506