



*To Protect and Promote the Health and the Environment of the People of Kittitas County*

February 24, 2023

Kelly Bacon, Kittitas County Planner I  
Community Development Services  
411 N. Ruby Street  
Ellensburg, WA. 98926

Dear Kelly,

Thank you for this opportunity to provide comments. Following are the Environmental Public Health comments on the CU-23-00001, 3BR Custom Cuts, notice of application. A well site inspection has been performed for this project. The applicant must obtain approval of the well as a Group B public water system through the Kittitas County Public Health Department and have a public water system ID# assigned by the Washington State Department of Health prior to using the system for the proposed business.

The applicant must apply for a site evaluation to be performed by the Public Health Department. When results have been received the applicant must work with a Washington State license on site sewage designer to create a design to be submitted to the Public Health Department for approval.

If you have any questions, please don't hesitate to give me a call.

Sincerely,

**Kim Shilley, Public Health Technician**

P: 509.962.7515 | F: 509.962.7581 | E: [kim.shilley@co.kittitas.wa.us](mailto:kim.shilley@co.kittitas.wa.us)

Kittitas County Public Health Department  
507 N Nanum St Suite 102, Ellensburg WA 98926

[www.co.kittitas.wa.us/health](http://www.co.kittitas.wa.us/health)

Please tell us how we're doing: [KCPHD Customer Survey](#)



507 N. Nanum Street, St. 102 · Ellensburg, WA 98926

T: 509.962.7515 · F: 509.962.7581

[www.co.kittitas.wa.us/health/](http://www.co.kittitas.wa.us/health/)