

From: [Joe Dietzel](#)
To: ["Chad Bala"](#); ["kcf1@fairpoint.net"](mailto:kcf1@fairpoint.net); [Darren Higashiyama](#); [Jeremiah Cromie](#)
Subject: Thorp Landing Subdivision
Date: Wednesday, April 26, 2023 2:49:19 PM
Attachments: [image001.png](#)

Good Afternoon,

After further review of the information regarding the 5 acre lots to be built on Thorp Landing Lane, the fire flow requirements and the fire hydrant system requirements are hereby waived. The lots are required to be sprinklered from the irrigation canal(s), the lots are low hazard WUIC scores, and the lots do not have a high ability to expose to other structures in the event of a fire. Thank you for your time.

Joseph A Dietzel

Kittitas County
Deputy Fire Marshal
509-962-7657
joe.dietzel@co.kittitas.wa.us



To schedule inspections: <https://www.co.kittitas.wa.us/cds/building/inspection-request.aspx> OR call (509) 962-7694

To view permit or inspection status: <https://co-kittitas-wa.smartgovcommunity.com/ApplicationPublic/ApplicationHome>

If this is a public records request, please go to: <https://www.co.kittitas.wa.us/request/default.aspx>

The information transmitted by this email is intended only for the person or entity to which it is addressed. This email may contain confidential and/or privileged material. If you are not the intended recipient of this message, be aware that any use, review, retransmission, distribution, or reproduction is strictly prohibited. If you received this in error, please contact the sender immediately and delete the material from all devices.
message id: 38eb45916c6dcbdac24bb8719d004a14