




KITTITAS COUNTY DEPARTMENT OF PUBLIC WORKS

TO: Dusty Pilkington, Planner I

COPY: Taylor Gustafson, Planner III
Candie Leader, Administrative Assistant

DATE: March 07, 2019

FROM: Mark R. Cook, Director 

RE: ACU-19-0001 Teanaway Cell Tower

Please see our comments regarding the proposed Teanaway Cell Tower listed below.

1. Access
The access roadway shall meet the current Kittitas County driveway standard. Greater than 150 feet in length requires a 16 foot all weather surface with two foot clear zones on each side.
2. Stormwater
The creation of greater than 5,000 square feet of new impervious area requires biofiltration swales along the perimeter edge of impervious surfaces allowing treatment and disposal of new impervious area.
3. Hazardous Slopes
The application suggests that potentially hazardous slopes are associated with the tower parcel. Improvement construction should avoid getting too close to steep slopes particularly where the infiltration of improved runoff is likely to occur.