

From: [Hayden, Kathryn E \(DOH\)](#)
To: [Mau, Russell E \(DOH\)](#); [Rachael Stevie \(CD\)](#)
Cc: [Holly Erdman](#); [Smits, Brenda M \(DOH\)](#)
Subject: RE: ACU-20-00002 Lockwood - Notice of Application
Date: Monday, September 28, 2020 8:14:25 AM
Attachments: [image002.png](#)
[image003.png](#)

Rachel,

The Department of Health Wastewater Management Section has the following comment:

The applicant indicates that the existing on-site septic system designed for a 3 bedroom residence will serve the Farm Stand. With the proposed use, it is unlikely that the existing system will be sufficient. Depending on size, the applicants will need to work with either the County Environmental Health Program or the DOH Wastewater Management Section on an appropriately sized on-site system.

Thank you,

Kathryn Hayden, P.E.

Environmental Engineer – LOSS Program
Wastewater Management Section
Office of Environmental Health and Safety
Washington State Department of Health
kathryn.hayden@doh.wa.gov
509.329.2147



From: Mau, Russell E (DOH) <Russell.Mau@DOH.WA.GOV>
Sent: Friday, September 25, 2020 11:46 AM
To: Rachael Stevie (CD) <rachael.stevie.cd@co.kittitas.wa.us>
Cc: Holly Erdman <Holly.erdman@co.kittitas.wa.us>; Smits, Brenda M (DOH) <brenda.smits@doh.wa.gov>; Hayden, Kathryn E (DOH) <kathryn.hayden@doh.wa.gov>
Subject: RE: ACU-20-00002 Lockwood - Notice of Application

Rachael:

The Department of Health (DOH) Office of Drinking Water (ODW) has the following comment:

For “Utilities”, the applicant indicates that water is available at the site – what is this source of water? This proposal looks like water use would generate the need for a public water system that would require submittal to either the County or DOH (depending the population number that has access to the water) for review and subsequent approval.

That constitutes DOH ODW comments.

Thanks,