



# **KITTITAS COUNTY**

## **DEPARTMENT OF PUBLIC WORKS**

---

### **MEMORANDUM**

---

---

TO: Community Development Services  
FROM: Public Works Planning Review Team  
DATE: February 11, 2021  
SUBJECT: ACU-20-00004 Hembree

#### **Public Works Pre-Application Comments**

- This application does not propose a change in access. If a change in access or addressing occurs, an access/address permit will be required from Public Works.
- Grading over 100 cubic yards of material requires a grading permit. Any grading over 500 cubic yards of material will require engineered grading and storm water plans. See Kittitas County Code chapter 14.05.
- Engineered stormwater plans are required if the project generates an impervious surface exceeding 5000 square feet. The stormwater system will comply with the Stormwater Management Manual for Eastern Washington (SWMMEW).

Please contact Kittitas County Public Works (509) 962-7523 with any questions.