

Kari Braniff

From: Joe Gilbert
Sent: Monday, August 25, 2008 8:53 AM
To: Kari Braniff
Subject: Young

Kari

The Young's are approved and finalized for a 4 bedroom residence on their current septic. Any New residence would require a additional septic system. Or a large modification to the current system. The Tanks of the current system are adequate for a 6 bedroom, but the drainfield is only sized for a 4-bedroom.

You can approve the ADU without septic, they won't get a building permit until the septic issue is resolved.

Please let me know if they want to contact me.

JOE GILBERT

Environmental Health Specialist II
Certified On-Site Wastewater Systems Inspector
Kittitas County Public Health
411 N Ruby St. Suite 3
Ellensburg, WA. 98926
Phone:(509) 933-8262 / Fax:(509) 962-7052
joe.gilbert@co.kittitas.wa.us

Public Health: Always Working for a Safer and Healthier Kittitas County

CONFIDENTIALITY NOTICE: This e-mail message and any attachments are for the sole use of the intended recipient(s) and may contain proprietary, confidential or privileged information. Any unauthorized review, use, disclosure or distribution is prohibited and may be a violation of law. If you are not the intended recipient or a person responsible for delivering this message to an intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.