

Jeff Watson

From: Erin Moore
Sent: Friday, June 14, 2013 9:35 AM
To: Jeff Watson
Subject: FW: Kittitas County Notice of Application AU-13-00003 Lund

Follow Up Flag: Follow up
Flag Status: Flagged

The comments from the Kittitas County Public Health Department are as follows:

Water- none
OSS- Needs a new septic system and reserve area for the proposed ADU.

Thanks Jeff!

Erin Moore

Permit Technician
Kittitas County Public Health
507 N Nanum St Suite 102
Ellensburg , WA 98926
Email: erin.moore@co.kittitas.wa.us
Phone : 509-962-7515
Fax: 509-962-7581

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14