

From: [Holly Duncan](#)
To: [Jeff Watson](#)
Subject: RE: BL-10-00030 Carpenter
Date: Monday, July 26, 2010 10:10:09 AM

Jeff,

The well must be 50 feet from the proposed property line. The drawing doesn't show the distance that will be.

Holly

From: Jeff Watson
Sent: Wednesday, July 21, 2010 2:51 PM
To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan
Subject: BL-10-00030 Carpenter

[BL-10-00030 Carpenter](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeff Watson
Planner I

Kittitas County Community Development
Services
411 N. Ruby Street, Suite 2
Ellensburg, WA 98926
jeff.watson@co.kittitas.wa.us
P: 509.933.8274
F: 509.962.7682



"Building Partnerships-Building Communities"

All e-mail sent to this address will be received by the Kittitas County e-mail system and may be subject to Public Disclosure under RCW Chapter 42.56 and is subject to archiving and review by someone other than the recipient.

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14