

From: [Holly Duncan](#)
To: [Jeff Watson](#)
Subject: RE: BL-11-00003 Brown
Date: Tuesday, February 22, 2011 2:53:15 PM

Jeff,

This looks OK as long as the proposed lines don't come within 50 feet of any existing wells. The 5 acre piece has a lot of structures and it is difficult to determine where the well is located.

Holly

From: Jeff Watson
Sent: Tuesday, February 15, 2011 9:14 AM
To: Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan
Subject: BL-11-00003 Brown

[BL-11-00003 Brown](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeff Watson
Planner I

Kittitas County Community Development
Services
411 N. Ruby Street, Suite 2
Ellensburg, WA 98926
jeff.watson@co.kittitas.wa.us
P: 509.933.8274
F: 509.962.7682



"Building Partnerships-Building Communities"

Disclosure under RCW Chapter 42.56 and is subject to archiving and review by someone other than the recipient.

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14