

## Jeff Watson

---

**From:** Holly Duncan  
**Sent:** Wednesday, February 27, 2013 10:50 AM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00024 Otte

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Good Morning Jeff,

Since this is a shared well between the two lots the 50 foot setback from the property line is not an issue. I am not sure how the drainfield got within the 100 foot radius.

Holly

---

**From:** Jeff Watson  
**Sent:** Monday, February 25, 2013 12:30 PM  
**To:** Holly Duncan  
**Subject:** RE: BL-11-00024 Otte

The whole file is [HERE](#)

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

**From:** Holly Duncan  
**Sent:** Monday, February 25, 2013 12:28 PM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00024 Otte

Oops, can you send me that last drawing again?

---

**From:** Jeff Watson  
**Sent:** Monday, February 25, 2013 12:17 PM  
**To:** Holly Duncan  
**Subject:** RE: BL-11-00024 Otte

I was wondering about that... those buffer rings are pretty ham dandy eh... what shall we do?

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby

Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

**From:** Holly Duncan  
**Sent:** Monday, February 25, 2013 12:15 PM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00024 Otte

50 feet. The existing well isn't even 100 feet from the existing drainfield.

---

**From:** Jeff Watson  
**Sent:** Monday, February 25, 2013 10:45 AM  
**To:** Holly Duncan  
**Subject:** RE: BL-11-00024 Otte

Here's what it looks like with the georeferenced image he sent over; how much space do you need?

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

**From:** Holly Duncan  
**Sent:** Monday, February 25, 2013 9:54 AM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00024 Otte

Jeff,

Is there a scale for the drawing so I know how far the proposed lot line is from the well?

Holly

---

**From:** Jeff Watson  
**Sent:** Monday, February 25, 2013 9:13 AM  
**To:** Holly Duncan  
**Subject:** RE: BL-11-00024 Otte

The applicant has sent the requested information for this one; the link below should still work.

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Ruby  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

**From:** Holly Duncan  
**Sent:** Tuesday, October 04, 2011 3:57 PM  
**To:** Jeff Watson  
**Subject:** RE: BL-11-00024 Otte

Jeff,

I also have questions on this one. It appears that the proposed project will have a lot line going through the area where the house, well site and drainfield might be. I need a better site plan showing the location of the well and on-site sewage system in relation to the proposed lot line. Can the applicant provide this?

Thank you.

Holly

---

**From:** Jeff Watson  
**Sent:** Tuesday, October 04, 2011 11:47 AM  
**To:** Christina Wollman; Brenda Larsen; Jan Ollivier; Holly Duncan  
**Subject:** BL-11-00024 Otte

[BL-11-00024 Otte](#)

Christina, Holly, and Brenda,

Could you please review this application for comment. Control Click on the hyperlink above (or go to the attachment tab in EDEN).

Thanks,

Jeffrey A. Watson  
Planner II  
[Kittitas County Public Works/Community Development Services](#)  
411 North Pearl  
Ellensburg WA 98926  
[jeff.watson@co.kittitas.wa.us](mailto:jeff.watson@co.kittitas.wa.us)  
509-933-8274

---

Notice: All email sent to this address will be received by the Kittitas County email system and may be subject to public disclosure under Chapter 42.56 RCW and to archiving and review.

message id: 38eb45916c6dcbdac24bb8719d004a14